ENERGY MANAGEMENT & MOLD PREVENTION – DAILY PROCEDURES

PLANT ENGINEER

BUILDING INSPECTION	
If you answer YES to any of the following questions, please notify Energy Management and/or Maintenance ASAP.	
1	Are there any leaks in your building(s)? (ceiling, under sinks, through windows or doors, etc.) Yes Door Location of Leak(s):
	LI 165 LI 110 LOCATION OF LEGAN(S).
2	Are there any doors or windows in your building(s) that are in need of weather stripping? ***The ability of light, moisture, or air to pass through the seal of a window or door indicates a weather stripping issue.
	☐ Yes ☐ No Location of weather stripping need(s):
3	Are there any thermostats in building(s) that are in a location that prevents it from getting an accurate reading of the room temperature? (blocked by a permanent fixture, directly under a vent, etc.)
	☐ Yes ☐ No Location of Thermostat(s):
DAI	LY CHECKLIST AND PROCEDURES
	 If not done already, turn off, unplug, and remove ALL forbidden plug loads from classrooms and offices. □ Personal Refrigerators □ Coffee Makers □ Lamps with INCANDESCENT BULBS
	☐ Microwaves ☐ Personal Heaters ☐ Lamps with INCANDESCENT BOLBS □ Microwaves ☐ Personal Heaters ***Lamps with CFL bulbs are permitted
	2. Ensure that ALL A/C unit air filters and drain pans are clean and unobstructed.
	3. Turn off ALL lights (except in areas where work is being done). ***Lights should be turned off when an area becomes unoccupied for any reason. (moving on to another task, breaks, etc.) ***Lights should be turned off in areas where windows and security lighting provide sufficient light for completing tasks.
	4. HVAC systems are in occupied mode ONLY during school hours and afterschool programs. ***Fans are permitted in any area.
	5. Turn off and UNPLUG all unused plug loads.
	6. ALL doors and windows are properly closed at ALL times. ***Doors & windows should NOT be propped open for ANY reason.
	7. ALL locker rooms, lockers, and their contents are clean and dry.
	8. There are no visible signs of condensation.
	9. Dehumidifiers are used in areas with high humidity levels.
	10. Ensure that ALL lights inlug loads are off and/or LINDLUGGED at the end of EVEDY day.

REMINDER

IF YOU NOTICE MOLD, OR AN INCREASED POTENTIAL FOR MOLD RELATED ISSUES, NOTIFY YOUR BUILDING SPECIALIST AND ENERGY MANAGER IMMEDIATELY!!!