

2

1

Height of the box is 8'

Doors shall be 36" wide and 78" tall.

Doors shall be centered on the wall they are on.


Panels shall be 4" thick.

Floor shall have 3/16" diamond tread.

Floor shall be reinforced to hold 2500 lb/sq.ft.

The entrance to the cooler shall be ramped after entering the door to allow carts to go from concrete pad into the cooler and freezer.

Bases of Design is Bally Refrigeration. Request for substitution shall be submitted to Greenville County Schools Procurement office by the inquiry deadline of the IFB.



B

A

UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN INCHES .XX = ±.0- .XXX = ±.00- .XXXX = ±.000-		NAME	DATE			
ANGULAR = ± ° FRACTIONAL = ±	DRAWN	BRANDON GUY	04/04/2024	TITLE		
SURFACE FINISH	CHECKED			Woodland Elementary Cooler and Freezer		
DO NOT SCALE DRAWING	APPROVED					
BREAK ALL SHARP EDGES AND REMOVE BURRS	MATERIAL	FINISH		SIZE	DWG NO.	
THIRD ANGLE PROJECTION					REV.	
					SCALE	1:40
					WEIGHT	
					SHEET	1 of 1

2

1

B

A